




INSTALLATION INSTRUCTIONS
 PLACE EXTENSION AGAINST FRONT OF SLEEVE
 ENSURE TOP AND SIDES ARE FLUSH
 ATTACH TO SLEEVE USING SELF TAPPING SCREWS PROVIDED
 IN 7 PLACES THREE IN THE TOP FLANGE AND TWO ON EACH SIDE

NOTE:
 WHEN INSTALLING THE UNIT PROVISIONS MUST BE MADE TO EXTEND THE
 OUTSIDE FRESH AIR AND CONDENSING AIR EXHAUST DIVIDERS TO REACH
 THE EXTERIOR LOUVER. IF THIS IS NOT DONE THE AIR WILL RECIRCULATE AND
 THE UNIT WILL NOT RUN PROPERLY AND MAY FAIL PREMATURELY.

**SLEEVE EXTENSION ADDS 2 3/8" DEPTH
 TO THE INSIDE
 OF A 16x42" SLEEVE**



				NAME		DATE		Applied COMFORT	
				DRAWN WWebber		24 Jul 2015			
				CHECKED				TITLE: SLEEVE EXTENSION INSTRUCTIONS	
				ENG APPR					
				MFG APPR					
				Q.A.					
				MATERIAL		COMMENTS:			
				FINISH					
REV	DATE	NOTES	BY						
APPLICATION			DC	NOT SCALE DRAWING					
SIZE		DWG. NO.		REV					
G		804053		00					
SCALE: 1:10		WEIGHT:		SHEET 1 OF 1					

PROPRIETARY AND CONFIDENTIAL
 THE INFORMATION CONTAINED IN THIS
 DRAWING IS THE SOLE PROPERTY OF
 <INSERT COMPANY NAME HERE>. ANY
 REPRODUCTION IN PART OR AS A WHOLE
 WITHOUT THE WRITTEN PERMISSION OF
 <INSERT COMPANY NAME HERE> IS
 PROHIBITED.